



PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITON

CERTIFICATE

No.....PHE/DLLB/23.24/117

Date: 10/07/2023

It is certified that an inspection team headed by SUKLESWAR BASUMATARY (Asstt. Chemist), Quality Manager D.L.L. Basugaon (P.H.E.D) Kokrajhar Div. No. II inspected the **GURUKUL NATIONAL SCHOOL, BASUGAON, WARD NO. 03, CHIRANG** on 03/07/2023 and found that the **GURUKUL NATIONAL SCHOOL, BASUGAON** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central/State/U.T Government.

The above valid for a period of 6 (six) months

Sly
Quality Manager
District Level Laboratory (PHE)
Signature with Seal: Kokrajhar Division No. II
Chirang
Name: SUKLESWAR BASUMATARY
Designation: Quality Manager

To,
The Principal
The Gurukul National School, Basugaon
Dist: Chirang



TC-10765

DISTRICT LEVEL LABORATORY, BASUGAON
Address: Office of the Executive Engineer (PHE), Kokrajhar Division No-II
Kajalgaon, Chirang
Email id- dllbasugaon@gmail.com

**Test Report**

Test Report No	: PHE /DLLB/23-24/117	Report Issue Date	: 10-07-2023
ULR No.	: TC107652300000117F	Client Ref No:	: DLB/July /17
Issued To	: Bijit Nath(Principal)	Pin Point Location	: Gurukul National School, Basugaon
Sample Description:	: Drinking Water	Block	: SidliChirang
Sample Type/Source	: Treated	VCDC	: Fulguri
Sample Collected By	: Bijit Nath(Principal)	Village	: Basugaon
Date of Receipt	: 03-07-2023	Habitation	: Basugaon
Test Start Date	: 03-07-2023		
Test End Date	: 05-06-2023		

Sr. No	Parameter	Protocol Used	Results	IS:10500:2012(SecondRevision)		Unit
				Desirable limit	MaxPermissibel imits	
1	Colour	IS 3025(Part4)	0	5	15	Hazen units
2	Odour	IS 3025(Part5)	Agreeable	Agreeable	Agreeable	-
3	pH	IS 3025(Part11)	6.90	6.5 to 8.5	No relaxation	-
4	Taste	IS 3025(Part8)	Agreeable	Agreeable	Agreeable	-
5	Turbidity	IS 3025(Part10)	0.8	1	5	NTU
6	Total dissolved solids	IS 3025(Part16)	80	500	2000	mg/l
7	Total Hardness	IS 3025(Part21)	72.81	200	600	mg/l
8	Total Alkalinity	IS 3025(Part23)	26	200	600	mg/l
9	Chloride	IS 3025(Part32)	18.43	250	1000	mg/l
10	Calcium	IS 3025(Part40)	17.35	75	200	mg/l
11	Magnesium	APHA -3500-Mg B 23rd Edition	7.17	30	100	mg/l
12	Sulphate	IS 3025(Part4)	3.80	200	400	mg/l
13	Nitrate	IS 3025(Part4)	Not tested	45	No relaxation	mg/l
14	Iron	APHA -3500-Fe B 23rd Edition	0.163	1	No relaxation	mg/l
15	Fluoride	APHA -4500-F D 23rd Edition	0.264	1	1.5	mg/l
16	Arsenic	IS 3025(Part37)	BDL	0.01	No relaxation	mg/l

Note:

- The test results given above are related to the sample received and tested in this laboratory. Reliability of the sample lies with the sender.
- This test report shall not be reproduced in whole or in part, without the written permission of laboratory.
- The test report cannot be used for any publicity or any legal purposes.
- The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by customer for retaining over a longer period.

.....END OF REPORT.....

Umapati (Microbiologist)
Sukteswar Basumatary
Tested by

*Sky*Reviewed By
Quality Manager

Sky
Authorized Signatory
Quality Manager
(Sukteswar Basumatary)
Quality Manager
District Level Laboratory (PHE)
Kokrajhar Division No.- II
Chirang